

Software manual

DULCOMETER®

Multi-parameter controller diaLog DACb

Modbus RTU

EN



Valid only in combination with the operating instructions for the Multi-parameter Controller diaLog DACb.

**Please carefully read these operating instructions before use. · Do not discard.
The operator shall be liable for any damage caused by installation or operating errors.
The latest version of the operating instructions are available on our homepage.**

General non-discriminatory approach

In order to make it easier to read, this document uses the male form in grammatical structures but with an implied neutral sense. It is aimed equally at both men and women. We kindly ask female readers for their understanding in this simplification of the text.

Supplementary information

➔ Please read the supplementary information in its entirety.

Information



This provides important information relating to the correct operation of the unit or is intended to make your work easier.

Warning information

Warning information include detailed descriptions of the hazardous situation.

The following symbols are used to highlight instructions, links, lists, results and other elements in this document:

Tab. 1: More symbols

Symbol	Description
1. ➔	Action, step by step.
⇒	Outcome of an action.
↪	Links to elements or sections of these instructions or other applicable documents.
■	List without set order.
[Button]	Display element (e.g. indicators). Operating element (e.g. button, switch).
'Display /GUI'	Screen elements (e.g. buttons, assignment of function keys).
CODE	Presentation of software elements and/or texts.

Table of contents

1	Modbus RTU implementation.....	4
1.1	General.....	4
1.2	Modbus RTU Message Structure.....	4
1.3	Modbus RTU Link Layer [<i>Link Layer</i>].....	5
1.4	Serial Connections.....	5
1.5	Modbus Connection Terminals.....	6
1.6	IEEE 32 bit floating point register.....	6
1.7	Supported Modbus commands.....	7
1.8	Register-Addresses-Numbering.....	7
1.9	Standard-Connection-Settings.....	8
1.10	Overview of the controller registers.....	8
2	Bit field values.....	13
2.1	Status of the channel.....	13
2.2	Error of the channel.....	14
2.3	Warning of the channel.....	15
2.4	Potential-free relay.....	16
2.5	Settings of the channel configuration.....	17
2.6	CRC-16 calculation.....	18

1 Modbus RTU implementation

1.1 General

This document contains general information regarding the implementation of the ProMinent diaLog Controller into the serial communication protocol of the Modbus RTU.

The ProMinent diaLog Controller acts as a slave device *[Device 1]*.

Communication between the ProMinent diaLog controllers *[Device 1]* and external master devices *[Device 0]* is possible, including e.g. PLC Programmable Logic Controller or PC.

The Modbus protocol is a communication protocol that enables devices to use data via a joint connection if the devices communicate with each other via the Modbus RTY RS-485 or RS-232 specification.

The diaLog Controller does not emulate every type of MODICON device.

The Modbus RTU specification describes the data link layer and physical layer.

The notification structure of the function codes uses Modbus RTU standards.

The IEEE 32 bit floating point numbers and whole numbers *[Integers]* are used.



Default settings

*The ProMinent diaLog controller is delivered to the customer with predetermined settings, with the **[address 1]** and a baud rate of 19200 baud*

You can set the slave address and the baud rate in the ProMinent diaLog controller via the set-up menu.

Implementation of the Modbus interface is based on the following standards:

- www.modbus.org/docs/Modbus_over_serial_line_V1_02.pdf

More information on Modbus can be found at www.modbus.org or other websites relating to the (local) Modbus organisation in your country (if available).

1.2 Modbus RTU Message Structure

Parameter	Value
Standard	RS-485 (preset) or RS-232
Coding system	8 bit
Broadcast support	Yes
Number of data bits per character	10 / 11 bits: 1 start bit 8 data bits 0 / 1 parity bits <i>[no, odd, even]</i> 1 / 2 stop bits (required 2 stop bits if no parity bit is used)

Parameter	Value
	predetermined value: [801]
Data rate (baud)	2400, 4800, 9600, 19200 (predetermined value), 38400, 57600, 115200
Error check	CRC-16 [<i>cyclic redundancy check</i>]; polynomial = 0x0A001 (1010000000000001)
Multi-byte transmission	byte sequence 0x1234 transfers 0x12 followed by 0x34
Message [TIMEOUT]	>= 3,5 characters (> 2 ms at a baud rate \geq 19200)
Slave address	1 ... 247 (1 is preset)

1.3 Modbus RTU Link Layer [*Link Layer*]

The link layer [*Link Layer*] comprises the following features:

- Slave address identification
- Start / end identification
- CRC-16 creation / check
- Buffer overflow detection
- Unused line detection
- Sending / receiving time limit for messages
- Raster setting error detection

Errors in messages that are received by the physical layer of the slave and are recognised, are ignored. The physical layer is restarted automatically if a new message is detected on the unused line.

1.4 Serial Connections

The ProMinent diaLog Modbus interface supports the following interface standards:

RS-485 (TIA-485-A)

- Half-duplex, 2-wire technology, twisted pair cable [*twisted pair*]
- Differential voltage level \pm 5 V.
- Cable length up to 1200 m
- Active termination.

RS-232 (TIA-232-F)


- Asynchronous serial transmission with voltages between -15 V ... +15 V.

The active cable termination and the interface mode can be changed via the ProMinent diaLog menu (SETUP > BUS configuration). The RS-485 mode is the predetermined interface.

1.5 Modbus Connection Terminals



If the interface is configured in the RS-485 mode and the dialog controller is an endpoint slave, the active termination must be activated in the control menu.



A2122


Fig. 1: Modbus Connection Terminals

The dialog Modbus RTU interface offers two connection terminals for the Modbus cabling.

The connection pins are connected electrically as follows: 1 = 1, 2 = 2; 3 = 3.

The device can be connected as an endpoint slave (either with one of the connections) or as *[Daisy-Chain-Slave]* (with both connections).

1.6 IEEE 32 bit floating point register



A2123

Fig. 2: Example of an IEEE 32 bit floating point register

The ProMinent dialog Modbus interface uses the IEEE 754 format for 32 bit floating point values (with single precision).

1.7 Supported Modbus commands

Tab. 2: The ProMinent diaLog Modbus interface supports the following commands:

Command	Function code	Maximum register number in one transaction
Read-Holding-Register	0x03 (3)	125
Write-Single-Register	0x06 (6)	1
Write-Multiple-Register	0x10 (16)	123
Read / Write-Multiple-Register	0x17 (23)	125 read / 121 write

Not all registers support all commands. Read-Only-Register [*Read-only*] can be only called up with function code 3.



Maximum message size

The maximum message size for the read-holding-register function [*Read Holding Registers*] is 100 byte with 9600 baud (200 byte at 19200 baud and 400 byte at 38400 baud). If this size is exceeded, the possibly damaged replies may be received.



Register 199

Register 199 can be used to test the byte interpretation corrected by the master for multi-byte values. [*Device 0*]

- If one of the writing registers triggers an exception, the value for all subsequent registers is ignored.
- If a byte parameter is read, the top 8 bit of the Modbus register become 0. If a byte parameter is written, the top 8 bit of the Modbus register must be set to 0.
- Long integer parameters [*Long-Integer-Parameter*] are 4 bytes long and are illustrated in two subsequent Modbus registers. The first register contains the bits 32 to 16. The second register contains the bits 15 to 0.
- Floating point parameters are 4 bytes long and are illustrated in two subsequent Modbus registers. Floating points are illustrated with simple precision IEEE format (1 sign bit, 8 bit exponent and 23 bit fraction). The first register contains the bits 32 to 16. The second register contains the bits 15 to 0.

1.8 Register-Addresses-Numbering



Maximum PDU size

The maximum PDU size is 253 bytes.

The register addresses numbering deviates from the Modbus RTU PDU numbering.

The Modbus PDU register address is register address 1.

The ProMinent diaLog register 100 is called up from a PDU address 99.

1.9 Standard-Connection-Settings



Access code [Service]

The access codes must be used to change these settings. [Service]

Tab. 3: This is the standard configuration ex factory for the ProMinent diaLog Modbus interface

Parameter	Standard value
Serial mode	RS-485 differential [differential]
Termination [Termination]	Disabled [disabled]
Serial format	8 data bits Odd parity [Odd parity] 1 stop bit (801)
Baud rate	19200 Baud
Slave address	1

The configuration can be modified in the menu of the diaLog controller via [SETUP > BUS-CONFIGURATION].

1.10 Overview of the controller registers

These tables contain the ProMinent diaLog register overview

PDU address (hex)	Register (decimal)	Parameter name	Format	Access R = Read W = Write	Info
Ausgehende Daten Kanal 1 / [Outgoing Data Channel 1]					
63	100	Actual Measured Value	FLOAT32	R	
65	102	Controller Actuating Value	INT16	R	[%]
66	103	Temperature	INT16	R	[0.1°C]
67	104	Actual Set Point	FLOAT32	R	
69	106	Actual External Disturbance Value	UINT16	R	[%]
6A	107	Status	UINT16	R	Bit coded
6B	108	Warnings	UINT16	R	Bit coded
6C	109	Actual Existing Errors	UINT32	R	Bit coded
6E	111	Actual Unconfirmed Errors	UINT32	R	Bit coded

¹: For use at a later point; ²: For use at a later point

R = Register is read-only; R/W = Register is read and write.

PDU address (hex)	Register (decimal)	Parameter name	Format	Access R = Read W = Write	Info
Ausgehende Daten Kanal 2 / [Outgoing Data Channel 2]					
70	113	Actual Measured Value	FLOAT32	R	
72	115	Controller Actuating Value	INT16	R	[%]
73	116	Temperature	UINT16	R	[0.1°C]
74	117	Actual Set Point	FLOAT32	R	
76	119	Actual External Disturbance Value	UINT16	R	[%]
77	120	Status	UINT16	R	Bit coded
78	121	Warnings	UINT16	R	Bit coded
79	122	Actual Existing Errors	UINT32	R	Bit coded
7B	124	Actual Unconfirmed Errors	UINT32	R	Bit coded
Ausgehende Daten Kanal 3 / [Outgoing Data Channel 3]					
F8	249	Actual Measured Value	FLOAT32	R	
FA	251	Controller Actuating Value	INT16	R	[%]
FB	252	Temperature	UINT16	R	[0.1°C]
FC	253	Actual Set Point	FLOAT32	R	
FE	255	Actual External Disturbance Value	UINT16	R	[%]
FF	256	Status	UINT16	R	Bit coded
100	257	Warnings	UINT16	R	Bit coded
101	258	Actual Existing Errors	UINT32	R	Bit coded
103	260	Actual Unconfirmed Errors	UINT32	R	Bit coded
Ausgehender Daten Mathematischer Kanal / [Outgoing Data Mathematic Channel]					
7D	126	Actual Measured Value	FLOAT32	R	
7F	128	Status	UINT16	R	
80	129	Warnings	UINT16	R	Bit coded
81	130	Actual Existing Errors ^[1]	UINT16	R	Bit coded
82	131	Actual Unconfirmed Errors ^[2]	UINT16	R	Bit coded

¹: For use at a later point; ²: For use at a later point

R = Register is read-only; R/W = Register is read and write.

Modbus RTU implementation

PDU address (hex)	Register (decimal)	Parameter name	Format	Access R = Read W = Write	Info
Hardware-Status / [<i>Hardware State</i>]					
83	132	Current Output 1	UINT16	R	[0.1 mA]
84	133	Current Output 2	UINT16	R	[0.1 mA]
85	134	Current Output 3	UINT16	R	[0.1 mA]
86	135	Dry Contact Relay	UINT16	R	Bit coded
87	136	Pump Relay 1 (MOSFET)	UINT16	R	Pulses / min
88	137	Pump Relay 2 (MOSFET)	UINT16	R	Pulses / min
89	138	Pump Relay 3 (MOSFET)	UINT16	R	Pulses / min
90	139	Pump Relay 4 (MOSFET)	UINT16	R	Pulses / min
Geräte-Information / [<i>Device Information</i>]					
8B	140	Firmware	UINT32	R	
8D	142	Firmware Channel 2	UINT32	R	
8F	144	Firmware Modbus Interface	UINT32	R	
91	146	Serial number	UINT32	R	
93	148	Revision	UINT16	R	
94	149	Revision Channel 2	UINT16	R	
95	150	Identity code [0-3]	UINT32	R	
97	152	Identity code [4-7]	UINT32	R	
99	154	Identity code [8-11]	UINT32	R	
9B	156	Identity code [12-15]	UINT32	R	
9D	158	Identity code [16-19]	UINT32	R	
9F	160	Identity code [20-23]	UINT32	R	
C5	198	Endian Test Value	UINT32	R	0xAABBCCDD
Regelung Kanal 1 / [<i>Control Channel 1</i>]					
C7	200	Stop	UINT16	R/W	Stop = 0xFFFF
C8	201	Pause	UINT16	R/W	1=Pause 2=Pause/ HOLD
1: For use at a later point; 2: For use at a later point R = Register is read-only; R/W = Register is read and write.					

PDU address (hex)	Register (decimal)	Parameter name	Format	Access R = Read W = Write	Info
Regelung Kanal 2 / [Control Channel 2]					
C9	202	Stop	UINT16	R/W	Stop = 0xFFFF
CA	203	Pause	UINT16	R/W	1=Pause 2=Pause/ [HOLD]
Regelung Kanal 3 / [Control Channel 3]					
105	262	Stop	UINT16	R/W	Stop = 0xFFFF
106	263	Pause	UINT16	R/W	1=Pause 2=Pause/ [HOLD]
Konfiguration Kanal 1 / [Configuration Channel 1]					
CB	204	Configuration	UINT16	R/W	Bit coded
CC	205	Remote Set Point	FLOAT32	R/W	
CE	207	Limit 1	FLOAT32	R/W	
D0	209	Limit 2	FLOAT32	R/W	
D2	211	Xp	FLOAT32	R/W	
D4	213	Ti	UINT16	R/W	0...9999 [s]
D5	214	Td	UINT16	R/W	0...999 [s]
D6	215	Additive Basic Load	UINT16	R/W	-100...+100 [%]
D7	216	Control Output Limitation	UINT16	R/W	1 = On
D8	217	Delay after Stop	UINT16	R/W	0...9999 [s]
D9	218	Delay after Reboot	UINT16	R/W	0...9999 [s]
DA	219	Remote Setpoint 2	FLOAT32	R/W	
Konfiguration Kanal 2 / [Configuration Channel 2]					
DC	221	Configuration	UINT16	R/W	Bit coded
DD	222	Remote Set Point	FLOAT32	R/W	
DF	224	Limit 1	FLOAT32	R/W	
E1	226	Limit 2	FLOAT32	R/W	
E3	228	Xp	FLOAT32	R/W	
E5	230	Ti	UINT16	R/W	0...9999 [s]
E6	231	Td	UINT16	R/W	0...999 [s]
E7	232	Additive Basic Load	INT16	R/W	-100...+100 [%]

1: For use at a later point; 2: For use at a later point

R = Register is read-only; R/W = Register is read and write.

PDU address (hex)	Register (decimal)	Parameter name	Format	Access R = Read W = Write	Info
E8	233	Control Output Limitation	UINT16	R/W	1 = on
E9	234	Delay after Stop	UINT16	R/W	0...9999 [s]
EA	235	Delay after Reboot	UINT16	R/W	0...9999 [s]
EB	236	Remote Setpoint 2	FLOAT32	R/W	
Konfiguration Kanal 3 / [Configuration Channel 3]					
107	264	Configuration	UINT16	R/W	Bit coded
108	265	Remote Set Point	FLOAT32	R/W	
10A	267	Limit 1	FLOAT32	R/W	
10C	269	Limit 2	FLOAT32	R/W	
10E	271	Xp	FLOAT32	R/W	
110	273	Ti	UINT16	R/W	0...9999 [s]
111	274	Td	UINT16	R/W	0...999 [s]
112	275	Additive Basic Load	INT16	R/W	-100...+100 [%]
113	276	Control Output Limitation	UINT16	R/W	1 = on
114	277	Delay after Stop	UINT16	R/W	0...9999 [s]
115	278	Delay after Reboot	UINT16	R/W	0...9999 [s]
116	279	Remote Setpoint 2	FLOAT32	R/W	
Konfiguration Mathematischer Kanal / [Configuration Mathematic Channel]					
ED	238	Configuration	UINT16	R/W	Bit coded
EE	239	Limit 1	FLOAT32	R/W	
F0	241	Limit 2	FLOAT32	R/W	
Fehler-Bestätigung / [Error Confirmation]					
F2	243	Error channel 1	UINT32	R/W	Bit coded
F4	245	Error channel 2	UINT32	R/W	Bit coded
F6	247	Error channel 3	UINT32	R/W	Bit coded
Kalibrieren / [Calibration]					
11A	283	Slope Channel 1	FLOAT32	R	
11C	285	Zero point Channel 1	FLOAT32	R	
11E	287	Slope Channel 2	FLOAT32	R	
120	289	Zero point Channel 2	FLOAT32	R	
122	291	Slope Channel 1	FLOAT32	R	
124	293	Zero point Channel 1	FLOAT32	R	

1: For use at a later point; 2: For use at a later point

R = Register is read-only; R/W = Register is read and write.

2 Bit field values

Bit field values are described here

2.1 Status of the channel

Bit	Description
15	1 = channel uses bus control parameters; 0 = channel uses internal parameters
14	
13	1 = error exists; 0 = no error
12	1 = warning exists; 0 = no warning
11	1 = SD card full; 0 = SD card not full
10	1 = SD card free < 20%; 0 = SD card free \geq 20%
9	1 = SD card exists; 0 = no SD card
8	1 = local control rate 2 active; 0 = local control rate 1 active
7	
6	
5	
4	
3	
2	
1	1 = local stop active; 0 = no local stop active
0	1 = channel active; 0 = channel inactive (or cannot be connected)

2.2 Error of the channel

Bit	Description
31	Error 99: There is a system error; <i>[A system error exists]</i>
30	
29	
28	
27	
26	
25	
24	
23	
22	
21	
20	Error 88: The connection to the extension module is faulty; <i>[The connection to the expansion module is faulty]</i>
19	Error 34: Incorrect correction variable; <i>[Incorrect correction variable]</i>
18	Error 19: The liquid level in storage tank 3 is too low; <i>[The level in tank 3 is too low]</i>
17	Error 18: The liquid level in storage tank 2 is too low; <i>[The level in tank 2 is too low]</i>
16	Error 17: The liquid level in storage tank 1 is too low; <i>[The level in tank 1 is too low]</i>
15	Error 16: The mA input is overloaded; <i>[The mA input is overloaded]</i>
14	Error 15: The mA input supply is overloaded; <i>[The mA input supply is overloaded]</i>
13	Error 14: The status of the controller is pause / hold <i>[PAUSE / HOLD]</i> ; <i>[The controller is in the state PAUSE / HOLD]</i>
12	Error 13: The status of the controller is pause <i>[PAUSE]</i> ; <i>[The controller is in the state PAUSE]</i>
11	Error 12: There is a sample water fault e.g. no flow; <i>[Error sample water exists, e. g. no flow]</i>
10	Error 11: After elapse of the delay period, a limit value error still exists; <i>[After elapsing of the delay time a limit error still exists]</i>
9	Error 10: The mA input current is less than 4 mA; <i>[The mA input current is less than 4 mA]</i>
8	Error 9: The mA input current is greater than 20 mA; <i>[The mA input current is greater than 20 mA]</i>
7	Error 8: The check time was infringed; <i>[The checkout time was infringed]</i>
6	Error 7: Check the mechanical condition (glass breakage) of the sensor; <i>[Check the mechanical status of the sensor Glass break is possible]</i>
5	Error 6: No sensor available; <i>[No sensor is available]</i>
4	Error 5: Calibration error exists; <i>[A calibration error exists]</i>
3	Error 4: The temperature is too high; <i>[The temperature is too high]</i>
2	Error 3: The temperature is too low; <i>[The temperature is too low]</i>
1	Error 2: The mV input voltage is too high; <i>[The mV input voltage is too high]</i>
0	Error 1: The mV input voltage is too low; <i>[The mV input voltage is too low]</i>

2.3 Warning of the channel

Bit	Description
15	
14	
13	
12	
11	
10	
9	
8	
7	
6	Warning 73: The fan has a fault; <i>[The fan has an error]</i>
5	Warning 72 The time must be checked; <i>[The time must be checked]</i>
4	Warning 71 The battery needs to be replaced; <i>[The battery must be replace]</i>
3	Warning 4 The measuring channel is not yet calibrated; <i>[The measuring channel is not yet calibrated]</i>
2	Warning 3 The wash timer has timed out. Maintenance is required; <i>[The wash timer has timed out. Maintenance is necessary]</i>
1	Warning 2 The limit value was exceeded; <i>[The limit was exceeded]</i>
0	Warning 1 The limit value was not reached; <i>[The limit was undershot]</i>

2.4 Potential-free relay

If relay output is active, then according bit is used.

Bit	Description
15	
14	
13	
12	
11	
10	
9	
8	
7	
6	
5	
4	
3	
2	Configuring alarm relay (XR3)
1	Relay 2 (XR2)
0	Relay 1 (XR1)

2.5 Settings of the channel configuration

Bit	Description
15	1 = Channel uses remote control parameters; 0 = Channel uses internal parameters; [1 = Channel uses remote control parameters; 0 = Channel uses internal parameters]
14	1 = Channel uses internal set 2; 0 = Channel uses internal set 1; [1 = Use internal parameter set 2; 0 = Use internal parameter set 1]
13	
12	
11	
10	
9	
8	1 = Limit value 2 configuration on; 0 = limit value 2 configuration off [1 = limit 2 configuration on; 0 = limit 2 configuration off]
7	1 = Limit value 1 configuration on; 0 = limit value 1 configuration off [1 = limit 1 configuration on; 0 = limit 1 configuration off]
6	0 = Control off;
5	[0 = Control off]
4	3 = P (1 way, decrease);
3	[3 = P (1 way, decrease)]
	6 = PID (1 way, increase) [6 = PID (1 way, increase)]
	9 = PID (2 way, dead zone) [9 = PID (2 way, deadzone)]
	1 = manual [1 = manual]
	4 = P (2 way, standard) [4 = P (2 way, standard)]
	7 = PID (1 way, decrease); [7 = PID (1 way, decrease)]
	2 = P (1 way, increase) [2 = P (1 way, increase)]
	5 = P (2 way, dead zone) [5 = P (2 way, deadzone)]
	8 = PID (2 way, standard) [8 = PID (2way, standard)]
2	
1	1 = Limit value 2 configuration high; 0 = limit value 2 configuration low; [1 = limit 2 configuration high; 0 = limit 2 configuration off]
0	1 = Limit value 1 configuration high; 0 = limit value 1 configuration low; [1 = limit 1 configuration high; 0 = limit 1 configuration off]

- Bit 14 is only valid if bit 15 = 0
- Bit 3, 4, 5, 6 are only valid if bit 15 = 1
- Bit 3, 4, 5, 6, 14, 15 only exists on channels 1 and 2

2.6 CRC-16 calculation

```
extern void calculate_CRC(unsigned char *message,  
int length, unsigned char *CRC)  
unsigned char CRCHi, CRCLo, TempHi, TempLo;  
static const unsigned char table[512] = {
```

```
0x00, 0x00, 0xC0, 0xC1, 0xC1, 0x81, 0x01, 0x40, 0xC3, 0x01, 0x03, 0xC0, 0x02,  
0x80, 0xC2, 0x41,
```

```
0xC6, 0x01, 0x06, 0xC0, 0x07, 0x80, 0xC7, 0x41, 0x05, 0x00, 0xC5, 0xC1, 0xC4,  
0x81, 0x04, 0x40,
```

```
0xCC, 0x01, 0x0C, 0xC0, 0x0D, 0x80, 0xCD, 0x41, 0x0F, 0x00, 0xCF, 0xC1, 0xCE,  
0x81, 0x0E, 0x40,
```

```
0x0A, 0x00, 0xCA, 0xC1, 0xCB, 0x81, 0x0B, 0x40, 0xC9, 0x01, 0x09, 0xC0, 0x08,  
0x80, 0xC8, 0x41,
```

```
0xD8, 0x01, 0x18, 0xC0, 0x19, 0x80, 0xD9, 0x41, 0x1B, 0x00, 0xDB, 0xC1, 0xDA,  
0x81, 0x1A, 0x40,
```

```
0x1E, 0x00, 0xDE, 0xC1, 0xDF, 0x81, 0x1F, 0x40, 0xDD, 0x01, 0x1D, 0xC0, 0x1C,  
0x80, 0xDC, 0x41,
```

```
0x14, 0x00, 0xD4, 0xC1, 0xD5, 0x81, 0x15, 0x40, 0xD7, 0x01, 0x17, 0xC0, 0x16,  
0x80, 0xD6, 0x41,
```

```
0xD2, 0x01, 0x12, 0xC0, 0x13, 0x80, 0xD3, 0x41, 0x11, 0x00, 0xD1, 0xC1, 0xD0,  
0x81, 0x10, 0x40,
```

```
0xF0, 0x01, 0x30, 0xC0, 0x31, 0x80, 0xF1, 0x41, 0x33, 0x00, 0xF3, 0xC1, 0xF2,  
0x81, 0x32, 0x40,
```

```
0x36, 0x00, 0xF6, 0xC1, 0xF7, 0x81, 0x37, 0x40, 0xF5, 0x01, 0x35, 0xC0, 0x34,  
0x80, 0xF4, 0x41,
```

```
0x3C, 0x00, 0xFC, 0xC1, 0xFD, 0x81, 0x3D, 0x40, 0xFF, 0x01, 0x3F, 0xC0, 0x3E,  
0x80, 0xFE, 0x41,
```

```
0xFA, 0x01, 0x3A, 0xC0, 0x3B, 0x80, 0xFB, 0x41, 0x39, 0x00, 0xF9, 0xC1, 0xF8,  
0x81, 0x38, 0x40,
```

```
0x28, 0x00, 0xE8, 0xC1, 0xE9, 0x81, 0x29, 0x40, 0xEB, 0x01, 0x2B, 0xC0, 0x2A,  
0x80, 0xEA, 0x41,
```

```
0xEE, 0x01, 0x2E, 0xC0, 0x2F, 0x80, 0xEF, 0x41, 0x2D, 0x00, 0xED, 0xC1, 0xEC,  
0x81, 0x2C, 0x40,
```

```
0xE4, 0x01, 0x24, 0xC0, 0x25, 0x80, 0xE5, 0x41, 0x27, 0x00, 0xE7, 0xC1, 0xE6,  
0x81, 0x26, 0x40,
```

```
0x22, 0x00, 0xE2, 0xC1, 0xE3, 0x81, 0x23, 0x40, 0xE1, 0x01, 0x21, 0xC0, 0x20,  
0x80, 0xE0, 0x41,
```

```
0xA0, 0x01, 0x60, 0xC0, 0x61, 0x80, 0xA1, 0x41, 0x63, 0x00, 0xA3, 0xC1, 0xA2,  
0x81, 0x62, 0x40,
```

```
0x66, 0x00, 0xA6, 0xC1, 0xA7, 0x81, 0x67, 0x40, 0xA5, 0x01, 0x65, 0xC0, 0x64,  
0x80, 0xA4, 0x41,
```

```
0x6C, 0x00, 0xAC, 0xC1, 0xAD, 0x81, 0x6D, 0x40, 0xAF, 0x01, 0x6F, 0xC0, 0x6E,  
0x80, 0xAE, 0x41,
```

```
0xAA, 0x01, 0x6A, 0xC0, 0x6B, 0x80, 0xAB, 0x41, 0x69, 0x00, 0xA9, 0xC1, 0xA8,  
0x81, 0x68, 0x40,
```

```
0x78, 0x00, 0xB8, 0xC1, 0xB9, 0x81, 0x79, 0x40, 0xBB, 0x01, 0x7B, 0xC0, 0x7A,  
0x80, 0xBA, 0x41,
```

0xBE, 0x01, 0x7E, 0xC0, 0x7F, 0x80, 0xBF, 0x41, 0x7D, 0x00, 0xBD, 0xC1, 0xBC, 0x81, 0x7C, 0x40,
0xB4, 0x01, 0x74, 0xC0, 0x75, 0x80, 0xB5, 0x41, 0x77, 0x00, 0xB7, 0xC1, 0xB6, 0x81, 0x76, 0x40,
0x72, 0x00, 0xB2, 0xC1, 0xB3, 0x81, 0x73, 0x40, 0xB1, 0x01, 0x71, 0xC0, 0x70, 0x80, 0xB0, 0x41,
0x50, 0x00, 0x90, 0xC1, 0x91, 0x81, 0x51, 0x40, 0x93, 0x01, 0x53, 0xC0, 0x52, 0x80, 0x92, 0x41,
0x96, 0x01, 0x56, 0xC0, 0x57, 0x80, 0x97, 0x41, 0x55, 0x00, 0x95, 0xC1, 0x94, 0x81, 0x54, 0x40,
0x9C, 0x01, 0x5C, 0xC0, 0x5D, 0x80, 0x9D, 0x41, 0x5F, 0x00, 0x9F, 0xC1, 0x9E, 0x81, 0x5E, 0x40,
0x5A, 0x00, 0x9A, 0xC1, 0x9B, 0x81, 0x5B, 0x40, 0x99, 0x01, 0x59, 0xC0, 0x58, 0x80, 0x98, 0x41,
0x88, 0x01, 0x48, 0xC0, 0x49, 0x80, 0x89, 0x41, 0x4B, 0x00, 0x8B, 0xC1, 0x8A, 0x81, 0x4A, 0x40,
0x4E, 0x00, 0x8E, 0xC1, 0x8F, 0x81, 0x4F, 0x40, 0x8D, 0x01, 0x4D, 0xC0, 0x4C, 0x80, 0x8C, 0x41,
0x44, 0x00, 0x84, 0xC1, 0x85, 0x81, 0x45, 0x40, 0x87, 0x01, 0x47, 0xC0, 0x46, 0x80, 0x86, 0x41,
0x82, 0x01, 0x42, 0xC0, 0x43, 0x80, 0x83, 0x41, 0x41, 0x00, 0x81, 0xC1, 0x80, 0x81, 0x40, 0x40,

```

CRCHi = 0xff;
CRCLo = 0xff;
while(length)
{
TempHi = CRCHi;
TempLo = CRCLo;
CRCHi = table[2 * (*message ^ TempLo)];
CRCLo = TempHi ^ table[(2 * (*message ^ TempLo))
+ 1];
message++;
length--; };
CRC [0] = CRCLo;
CRC [1] = CRCHi;
return;
}

```



ProMinent GmbH
Im Schuhmachergewann 5 - 11
69123 Heidelberg, Germany
Telephone: +49 6221 842-0
Fax: +49 6221 842-419
Email: info@prominent.com
Internet: www.prominent.com

982017, 1, en_GB